



**ADDENDUM 001
REQUEST FOR QUOTATION
Seal Joint Replacement
D609-077-RW**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original quote. The due date for receipt of this quotation changes by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Terri Mount Sr. General Services Specialist
Bidder Signature	Department of Transportation
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: 2-18-09

EXTENSION OF QUOTATION CLOSING:

RESPONSES TO THE ABOVE QUOTATION HAVE BEEN EXTENDED TO FEBRUARY 25, 2009 BY 10:00 A.M. RESPONSES MAY BE FAXED.

FURTHER CLARIFICATIONS:

Concrete sealing material will be a "Qualified Protective Coating-Concrete Bents and Piers", Urethane or Epoxy as referenced in Missouri Standard Specification Section 711.3.1 or 711.3.2 (attached). The material color shall be clear or resemble that of cured concrete. All construction material requirements shall be as listed in Section 711. The approved products may be found on MoDOT's website under "Protective Coating Material: Field Section (FS) 1059 Table 1 or 2, (attached). No asphalt based sealers will be allowed as previously noted.

THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFQ.